

STEP DUMBEA 2 - RAPPORT MENSUEL D'ACTIVITE

DONNEES AUTOSURVEILLANCE

Dates	CHARGE HYDRAULIQUE	CONCENTRATIONS MESUREES A L'ENTREE								CONCENTRATIONS MESUREES A LA SORTIE														
	Volume entrant (m ³ /j)	pH	NNO3 (mg/l)	NTK (mg/l)	NGL (mg/l)	P (mg/l)	DBO5 (mg/l)	MES (mg/l)	DCO (mg/l)	pH	TAC (°f)	NNH4 (mg/l)	NNO3 (mg/l)	NGL (mg/l)	NTK (mg/l)	P (mg/l)	DBO5 (mg/l)	MES (mg/l)	DCO (mg/l)					
Valeur limite ICPE																				ICPE 15 CONTRAT : 10	ICPE : 7 CONTRAT : 4	ICPE : 25 CONTRAT : 15	ICPE : 35 CONTRAT : 30	ICPE : 125 CONTRAT : 60
06/03/2018	3 880	7,1	0,2	62,8	63,0	7,5	330	267	598	7,1	13,8	1,3	6,0	9,1	2,3	1,4	3	5	28					
13/03/2018	5 492	7,5	0,3	25,4	26,0	3,1	120	113	251															

mars-18