

STEP DUMBEA 2 - RAPPORT MENSUEL D'ACTIVITE

DONNEES AUTOSURVEILLANCE

Dates	CHARGE HYDRAULIQUE	CONCENTRATIONS MESUREES A L'ENTREE								CONCENTRATIONS MESUREES A LA SORTIE														
	Volume entrant (m ³ /j)	pH	NNO3 (mg/l)	NTK (mg/l)	NGL (mg/l)	P (mg/l)	DBO5 (mg/l)	MES (mg/l)	DCO (mg/l)	pH	TAC (°f)	NNH4 (mg/l)	NNO3 (mg/l)	NGL (mg/l)	NTK (mg/l)	P (mg/l)	DBO5 (mg/l)	MES (mg/l)	DCO (mg/l)					
Valeur limite ICPE																				ICPE 15 CONTRAT : 10	ICPE : 7 CONTRAT : 4	ICPE : 25 CONTRAT : 15	ICPE : 35 CONTRAT : 30	ICPE : 125 CONTRAT : 60
03/05/2018	4 090	7,6	0,2	65,2	65,7	5,5	251	310	627	7,4	20,4	2,9	1,6	9,5	2,9	1,0	2	2	30					
15/05/2018	4 270	7,6	34,0	30,2	64,4	10,0	200	133	402															

mai-18